

## White Rock Water Sampling Summary Results -May 18 2016

Sample Location	Date Sampled	METALS					BACTERIA	
		Arsenic	Copper	Lead	Iron	Manganese	Total Coliforms	Escherichia Coli
Units		mg/L	mg/L	mg/L	mg/L	mg/L	MPN/100mL	MPN/100mL
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001	1.0	1.0
Guideline Allowable Limit		0.0100	1.000	0.0100	0.300	0.050	0.0	0.0
14800 Blk. Buena Vista Avenue (Main Shop)	17-May-16	0.0096	0.013	<0.0001	<0.005	0.009	<1.0	<1.0
Everall Station	17-May-16	0.0065	0.001	<0.0001	<0.005	0.090	<1.0	<1.0
Malabar Station	17-May-16	0.0062	0.003	0.0001	<0.005	0.020	<1.0	<1.0
Mann Park Station	17-May-16	0.0064	0.010	<0.0001	0.005	0.036	<1.0	<1.0
Marine Station	17-May-16	0.0058	0.008	0.0002	<0.005	0.009	<1.0	<1.0
Merklin Reservoir-25% Level	17-May-16	0.0096	<0.001	<0.0008	<0.005	0.117	<1.0	<1.0
Merklin Reservoir-50% Level	17-May-16	0.0095	0.001	<0.0001	<0.005	0.116	<1.0	<1.0
Merklin Reservoir-75% Level	17-May-16	0.0096	<0.001	<0.0008	<0.005	0.117	<1.0	<1.0
Roper Station	17-May-16	0.0065	0.001	<0.0001	<0.005	0.067	<1.0	<1.0
Russell Ave Station	17-May-16	0.0064	0.001	0.0003	<0.005	0.056	<1.0	<1.0
Stayte Station	17-May-16	0.0088	0.009	0.0014	<0.005	0.006	<1.0	<1.0
Stevens Station	17-May-16	0.0085	0.003	<0.0001	<0.005	0.104	<1.0	<1.0
WR Washroom	17-May-16	0.0091	0.077	0.0015	0.030	0.007	<1.0	<1.0