

Metal Results 2017

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0002	0.001	0.0001	0.005	0.001
Guideline Limit		0.0100	1	0.01	0.3	0.05
15600 Blk. Marine Drive	20-Jan-17	0.0075	0.0190	0.000116	0.006	0.029
15200 Blk. Marine Drive	23-Jan-17	0.0057	0.0026	0.000022	<0.004	0.031
Oxford Well #1	25-Jan-17	0.0067	0.0005	0.000276	0.005	0.058
Oxford Well #2	25-Jan-17	0.0046	0.0049	0.000129	<0.004	0.002
Oxford Well #3	25-Jan-17	0.0062	0.0012	0.000065	0.004	0.181
High St Well #4	25-Jan-17	0.0027	0.0012	0.001030	0.054	0.187
Buena Vista Well #5	25-Jan-17	0.0079	0.0023	0.000096	0.022	0.012
Merklin Well #6	25-Jan-17	0.0086	<0.0005	0.000099	0.005	0.142
Merklin Well #7	25-Jan-17	0.0080	0.0010	0.000178	0.007	0.111
15000 Blk. Russell Ave	31-Jan-17	0.0056	0.125	0.001470	0.020	0.086
1400 Blk. Martin St	06-Feb-17	0.0057	0.0070	0.000014	<0.004	0.057
1400 Blk. Vidal St	09-Feb-17	0.0059	0.0083	0.000180	<0.004	0.061
15100 Blk. Prospect Ave	21-Feb-17	0.0066	0.0042	0.000036	<0.004	0.028
1300 Blk. Foster St	02-Mar-17	<0.0001	0.0010	0.000185	<0.004	0.029
15100 Blk. B-Vista	13-Mar-17	0.0068	0.0115	0.000057	<0.004	0.128
Well #6	14-Mar-17	0.0088	Monthly Merklin Arsenic Sampling			
Well #7	14-Mar-17	0.0081				
15000 Blk. Victoria Ave	28-Mar-17	0.0062	0.0083	0.000227	0.010	0.020
1200 Blk. Foster St	30-Mar-17	0.0061	0.0098	0.000069	<0.004	0.017