

Metal Results

Sample Location	Date	Metals	Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments	Pass/ Fail
Well #1 Oxford Street	17-Nov-15	Arsenic	mg/L	0.0040	0.0002	0.010	Below MAC	Pass
	17-Nov-15	Copper	mg/L	0.005	0.001	1.0	Below AO	Pass
	17-Nov-15	Lead	mg/L	0.0046	0.0001	0.01	Below MAC	Pass
	17-Nov-15	Iron	mg/L	0.006	0.005	0.3	Below AO	Pass
	17-Nov-15	Manganese	mg/L	0.043	0.001	0.05	Below AO	Pass
Well #2 Oxford Street	17-Nov-15	Arsenic	mg/L	0.0045	0.0002	0.010	Below MAC	Pass
	17-Nov-15	Copper	mg/L	0.005	0.001	1.0	Below AO	Pass
	17-Nov-15	Lead	mg/L	0.0001	0.0001	0.01	Below MAC	Pass
	17-Nov-15	Iron	mg/L	0.085	0.005	0.3	Below AO	Pass
	17-Nov-15	Manganese	mg/L	0.003	0.001	0.05	Below AO	Pass
Well #3 Oxford Street	17-Nov-15	Arsenic	mg/L	0.0043	0.0002	0.010	Below MAC	Pass
	17-Nov-15	Copper	mg/L	0.009	0.001	1	Below AO	Pass
	17-Nov-15	Lead	mg/L	0.0003	0.0001	0.01	Below MAC	Pass
	17-Nov-15	Iron	mg/L	0.612	0.005	0.3	Above AO	Fail
	17-Nov-15	Manganese	mg/L	0.014	0.001	0.05	Below AO	Pass
Well #4 High Street	18-Nov-15	Arsenic	mg/L	0.0027	0.0002	0.010	Below MAC	Pass
	18-Nov-15	Copper	mg/L	0.007	0.001	1.0	Below AO	Pass
	18-Nov-15	Lead	mg/L	0.0128	0.0001	0.01	Above MAC	Fail
	18-Nov-15	Iron	mg/L	0.258	0.005	0.3	Below AO	Pass
	18-Nov-15	Manganese	mg/L	0.020	0.001	0.05	Below AO	Pass
Well #4 High Street Retest from Nov 18, 2015	30-Nov-15	Arsenic	mg/L	0.0038	0.0002	0.010	Below MAC	Pass
	30-Nov-15	Copper	mg/L	0.001	0.001	1.00	Below AO	Pass
	30-Nov-15	Lead	mg/L	0.0006	0.0001	0.01	Below MAC	Pass
	30-Nov-15	Iron	mg/L	0.636	0.005	0.3	Above AO	Fail
	30-Nov-15	Manganese	mg/L	0.170	0.001	0.05	Above AO	Fail
Well #5 Buena Vista Ave	17-Nov-15	Arsenic	mg/L	0.0083	0.0002	0.010	Below MAC	Pass
	17-Nov-15	Copper	mg/L	0.012	0.001	1.0	Below AO	Pass
	17-Nov-15	Lead	mg/L	0.0003	0.0001	0.01	Below MAC	Pass
	17-Nov-15	Iron	mg/L	<0.005	0.005	0.3	Below AO	Pass
	17-Nov-15	Manganese	mg/L	0.004	0.001	0.05	Below AO	Pass
Well #6 Merklin Street	17-Nov-15	Arsenic	mg/L	0.0091	0.0002	0.010	Below MAC	Pass
	17-Nov-15	Copper	mg/L	0.005	0.001	1.0	Below AO	Pass
	17-Nov-15	Lead	mg/L	0.0009	0.0001	0.01	Below MAC	Pass
	17-Nov-15	Iron	mg/L	0.010	0.005	0.3	Below AO	Pass
	17-Nov-15	Manganese	mg/L	0.138	0.001	0.05	Above AO	Fail
Well #7 Merklin Street	17-Nov-15	Arsenic	mg/L	0.0083	0.0002	0.010	Below MAC	Pass
	17-Nov-15	Copper	mg/L	<0.001	0.001	1.0	Below AO	Pass
	17-Nov-15	Lead	mg/L	0.0004	0.0001	0.01	Below MAC	Pass
	17-Nov-15	Iron	mg/L	<0.005	0.005	0.3	Below AO	Pass
	17-Nov-15	Manganese	mg/L	0.109	0.001	0.05	Above AO	Fail