

Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0001	0.0005	0.00001	0.004	0.001
Guideline Limit		0.010	1.0	0.01	0.3	0.05
Customer Concern #1	18-Jan-18	0.0068	0.0049	0.00012	<0.004	0.065
Well #1	18-Jan-18	0.0071	0.0056	0.00035	<0.004	0.073
Well #2	18-Jan-18	0.0049	0.0041	<0.00001	<0.004	0.004
Well #3	18-Jan-18	0.0065	0.0005	0.00023	0.006	0.21
Well #4	18-Jan-18	0.0027	0.0048	0.00239	0.085	0.21
Well #6	18-Jan-18	0.0094	<0.0005	0.00004	<0.004	0.15
Well #7	18-Jan-18	0.0085	<0.0005	0.00114	<0.004	0.12
Well #8	18-Jan-18	0.0069	<0.0005	0.00003	0.005	0.18
Well #6	28-Feb-18	0.0089	Monthly Arsenic Sampling			
Well #7	28-Feb-18	0.00998				
Well #6	28-Mar-18	0.0089	Monthly Arsenic Sampling			
Well #7	28-Mar-18	0.0082				
Well #6	25-Apr-18	0.0097	Monthly Arsenic Sampling			
Well #7	25-Apr-18	0.0092				
Customer Concern #2	15-May-18	0.0056	0.0102	0.00006	0.006	0.031
Well #1	31-May-18	0.0071	0.0036	0.00010	<0.004	0.055
Well #2	31-May-18	0.0045	0.0039	0.00002	0.005	0.004
Well #3	31-May-18	0.0064	0.0009	0.00015	0.006	0.20
Well #6	31-May-18	0.0091	0.0012	0.00007	<0.004	0.14
Well #7	31-May-18	0.0085	<0.0005	0.00069	0.006	0.12
Well #8	31-May-18	0.0070	0.0012	0.00004	0.0098	0.17
Well #6	27-Jun-18	0.0087	Monthly Arsenic Sampling			
Well #7	27-Jun-18	0.0081				
Customer Concern #3	18-Jul-18	0.0058	0.0018	0.00017	<0.004	0.037
Well #1	25-Jul-18	0.0064	0.0044	0.00011	<0.004	0.056
Well #2	25-Jul-18	0.0043	0.0034	0.00003	0.006	0.005
Well #3	25-Jul-18	0.0055	<0.0005	0.00010	<0.004	0.16
Well #6	25-Jul-18	0.0087	0.0015	0.00005	<0.004	0.15
Well #7	25-Jul-18	0.0082	<0.0005	0.00041	<0.004	0.12
Well #8	25-Jul-18	0.0058	0.0026	0.00123	0.014	0.13
Customer Concern #4	13-Aug-18	0.0066	0.0053	0.00030	0.008	0.076
Customer Concern #5	28-Aug-18	0.0065	0.0065	0.00016	<0.004	0.14
Customer Concern #6	28-Aug-18	0.0065	0.0216	0.00004	<0.004	0.15
Customer Concern #7	29-Aug-18	0.0079	0.0086	0.00001	<0.004	0.13
Well #6	29-Aug-18	0.0087	Monthly Arsenic Sampling			
Well #7	29-Aug-18	0.0081				
Well #4 Flow Test*	30-Aug-18	0.0021	0.0016	0.00057	0.038	0.21
Customer Concern #8	04-Sep-18	0.0085	0.0033	0.00014	<0.004	0.13
Customer Concern #9**	05-Sep-18	0.0069	0.0295	0.02118	0.014	0.14
Customer Concern #10	05-Sep-18	0.0081	0.0042	0.00010	<0.004	0.13
Customer Concern #11	06-Sep-18	0.0072	0.0081	0.00045	<0.004	0.12
Customer Concern #12	07-Sep-18	0.0070	0.0044	0.00021	<0.004	0.12

Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0001	0.0005	0.00001	0.004	0.001
Guideline Limit		0.010	1.0	0.01	0.3	0.05
Customer Concern #9***	10-Sep-18	0.0066	0.0065	0.00021	<0.004	0.12
Customer Concern #9***	10-Sep-18	0.0065	0.0041	0.00010	<0.004	0.12
Customer Concern #9***	10-Sep-18	0.0065	0.0053	0.00018	<0.004	0.12
Customer Concern #9***	10-Sep-18	0.0066	0.0063	0.00029	<0.004	0.12
Customer Concern #13	11-Sep-18	0.0060	0.0046	0.00004	<0.004	0.11
Customer Concern #14	11-Sep-18	0.0061	0.0077	0.00006	<0.004	0.11
Customer Concern #15	12-Sep-18	0.0061	0.0090	0.00004	<0.004	0.12
Customer Concern #16	17-Sep-18	0.0059	0.0050	0.00014	<0.004	0.11
Customer Concern #17	18-Sep-18	0.0060	0.0102	0.00006	0.063	0.026
Customer Concern #18	24-Sep-18	0.0064	0.0078	<0.00001	<0.004	0.13
Well #6	26-Sep-18	0.0083	Monthly Arsenic Sampling			
Well #7	26-Sep-18	0.0079				
Customer Concern #19	26-Sep-18	0.0064	0.0068	0.00010	<0.004	0.12
Customer Concern #20****	01-Oct-18	0.0060	0.0020	0.00008	<0.004	0.11
Customer Concern #20****	01-Oct-18	0.0060	0.0174	0.00008	<0.004	0.11
Customer Concern #20****	01-Oct-18	0.0059	0.0121	0.00057	<0.004	0.11
Customer Concern #20****	02-Oct-18	0.0065	0.0055	0.00009	<0.004	0.12
Customer Concern #21	01-Oct-18	0.0060	0.0020	0.00008	<0.004	0.11
Customer Concern #22	04-Oct-18	0.0058	0.0215	0.00013	0.004	0.10
Customer Concern #23	10-Oct-18	0.0064	0.0162	0.00179	<0.004	0.093
Customer Concern #24	15-Oct-18	0.0064	0.0060	0.00018	0.008	0.094
Customer Concern #25	22-Oct-18	0.0083	0.0130	0.00006	0.006	0.13
Customer Concern #26	25-Oct-18	0.0087	0.0080	0.00016	0.007	0.12
Customer Concern #27	22-Nov-18	0.0054	0.0067	0.00003	<0.004	0.084
Customer Concern #28	22-Nov-18	0.0053	0.0063	0.00005	<0.004	0.080
Centennial Arena*	28-Nov-18	0.0054	0.0189	0.00010	<0.004	0.082
CAL*	28-Nov-18	0.0053	0.0440	0.00015	0.005	0.089
WR Community Centre*	28-Nov-18	0.0054	0.0449	0.00005	<0.004	0.093
City Hall - Annex*	28-Nov-18	0.0071	0.0021	0.00005	<0.004	0.12
City Hall - main*	28-Nov-18	0.0065	0.0088	0.00012	<0.004	0.11
RCMP*	28-Nov-18	0.0078	0.0466	0.00012	0.005	0.089
Fire Hall*	28-Nov-18	0.0069	0.0066	0.00009	<0.004	0.12
Evergreen Daycare*	28-Nov-18	0.0076	0.0132	0.00003	<0.004	0.11
Library*	28-Nov-18	0.0073	0.0280	0.00035	0.005	0.10
Kent Activity Center*	28-Nov-18	0.0081	0.0070	0.00005	<0.004	0.13
Operations Bldg*	28-Nov-18	0.0063	0.1286	0.00049	<0.004	0.085
Museum*	28-Nov-18	0.0067	0.0779	0.00113	<0.004	0.11
Well #6	29-Nov-18	0.0092	Monthly Arsenic Sampling			
Well #7	29-Nov-18	0.0086				

Metal Results 2018

Sample Location	Date Sampled	Arsenic	Copper	Lead	Iron	Manganese
		mg/L	mg/L	mg/L	mg/L	mg/L
Nominal Detection Limit		0.0001	0.0005	0.00001	0.004	0.001
Guideline Limit		0.010	1.0	0.01	0.3	0.05
Customer Concern #29	04-Dec-18	0.0088	0.0038	0.00012	0.010	0.13
Customer Concern #30 Pre*****	10-Dec-18	0.0069	0.0050	0.00041	0.007	0.10
Customer Concern 30 Post*****	10-Dec-18	0.0069	0.0007	0.00021	<0.004	<0.001
Customer Concern #31	21-Dec-18	0.0085	0.0058	0.00008	<0.004	0.13
Well #6	28-Dec-18	0.0087	Monthly Arsenic Sampling			
Well #7	28-Dec-18	0.0083				

* Also under Non-Routine results

** 4 resamples taken immediately after results

*** Resampling results

**** 4 Samples taken from same address

***** Resident has home filter system, results pre- and post-filter