

Non Routine Water Quality Results for Source and Distribution Water 2016

Sampling Point Name	Date Sampled	TC	E-coli	Comments
		MPN / 100 ml	MPN / 100 ml	
13700 Blk. Malabar Avenue	14-Jan-16	<1.0	<1.0	Below MAC
Peace Arch Elementary School	20-Jan-16	<1.0	<1.0	Below MAC
Merklin By-Pass Line	25-Jan-16	<1.0	<1.0	Below MAC
Merklin By-Pass Line	26-Jan-16	<1.0	<1.0	Below MAC
800 Blk. Stevens Street	15-Feb-16	<1.0	<1.0	Below MAC
Well #2	15-Feb-16	<1.0	<1.0	Below MAC
Well #2	16-Feb-16	<1.0	<1.0	Below MAC
1000 Blk. Foster Street	9-Mar-16	<1.0	<1.0	Below MAC
1000 Blk. Foster Street	9-Mar-16	<1.0	<1.0	Below MAC
900 Blk. Foster Street	13-May-16	<1.0	<1.0	Below MAC
15900 Blk Roper Ave	2-Jun-16	<1.0	<1.0	Below MAC
1100 Blk Centre Street	2-Jun-16	<1.0	<1.0	Below MAC
1300 Blk Fir Street	29-Jun-16	<1.0	<1.0	Below MAC
Well #1	5-Jul-16	1.0	<1.0	Above MAC
Well #1	13-Jul-16	<1.0	<1.0	Below MAC
15900 Blk Vine Ave	26-Jul-16	<1.0	<1.0	Below MAC
15100 Blk Thrift Ave	27-Jul-16	<1.0	<1.0	Below MAC
Chestnut Station	28-Jul-16	<1.0	<1.0	Below MAC
15900 Blk Vine Ave	28-Jul-16	<1.0	<1.0	Below MAC
1100 Blk Keil Cres	11-Aug-16	<1.0	<1.0	Below MAC
1300 Blk George St	23-Aug-16	<1.0	<1.0	Below MAC
Kent Street Activity Center	6-Sep-16	<1.0	<1.0	Below MAC
15400 Blk Roper Avenue	4-Nov-16	<1.0	<1.0	Below MAC
Kent Street Activity Center	4-Nov-16	<1.0	<1.0	Below MAC
Stevens Station	13-Dec-16	<1.0	<1.0	Below MAC