

THM & HAA RESULTS 2017

| Sample | Unit of Measure | Nominal Detection Limit | Sample Location | | | | | | Sampled Date |
|-------------------------------|-----------------|-------------------------|-----------------|----------------|------------------|----------------|-----------------|------------------|--------------|
| | | | Stevens Station | Stayte Station | Roper PRV - High | Marine Station | Everall Station | Mann Park Sation | |
| Chloroform | mg/L | 0.001 | <0.001 | <0.001 | <0.001 | <0.001 | - | - | Jan 31 2017 |
| Bromodichloromethane | mg/L | 0.001 | <0.001 | <0.001 | <0.001 | <0.001 | - | - | Jan 31 2017 |
| Dibromochloromethane | mg/L | 0.001 | <0.001 | <0.001 | <0.001 | <0.001 | - | - | Jan 31 2017 |
| Bromoform | mg/L | 0.001 | <0.001 | <0.001 | <0.001 | 0.001 | - | - | Jan 31 2017 |
| Total THMs | mg/L | 0.001 | <0.001 | <0.001 | <0.001 | 0.001 | - | - | Jan 31 2017 |
| Dibromofluoromethane | % | 86-118 | 94 | 98 | 96 | 91 | - | - | Jan 31 2017 |
| Toluene-d8 | % | 85-115 | 99 | 100 | 100 | 99 | - | - | Jan 31 2017 |
| Bromofluorobenzene | % | 86-115 | 96 | 95 | 97 | 96 | - | - | Jan 31 2017 |
| Monochloroacetic Acid | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |
| Monobromoacetic Acid | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |
| Dichloroacetic Acid | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |
| Bromochloroacetic Acid | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |
| Dibromoacetic Acid | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |
| Trichloroacetic Acid | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |
| Total HAA6 | ug/L | 2 | <2.0 | <2.0 | <2.0 | <2.0 | - | - | Jan 31 2017 |