

THM & HAA RESULTS 2017

Sample	Unit of Measure	Nominal Detection Limit	Sample Location						Sampled Date
			Stevens Station	Stayte Station	Roper PRV - High	Marine Station	Everall Station	Mann Park Sation	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	Jan 31 2017
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	Jan 31 2017
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	Jan 31 2017
Bromoform	mg/L	0.001	<0.001	<0.001	<0.001	0.001	-	-	Jan 31 2017
Total THMs	mg/L	0.001	<0.001	<0.001	<0.001	0.001	-	-	Jan 31 2017
Dibromofluoromethane	%	86-118	94	98	96	91	-	-	Jan 31 2017
Toluene-d8	%	85-115	99	100	100	99	-	-	Jan 31 2017
Bromofluorobenzene	%	86-115	96	95	97	96	-	-	Jan 31 2017
Monochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Monobromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Dichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Bromochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Dibromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Trichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Total HAA6	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Jan 31 2017
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	Apr 26 2017
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	Apr 26 2017
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	0.002	-	-	Apr 26 2017
Bromoform	mg/L	0.001	<0.001	<0.001	<0.001	0.004	-	-	Apr 26 2017
Total THMs	mg/L	0.001	<0.001	<0.001	<0.001	0.006	-	-	Apr 26 2017
Dibromofluoromethane	%	86-118	93	91	95	98	-	-	Apr 26 2017
Toluene-d8	%	85-115	100	99	98	100	-	-	Apr 26 2017
Bromofluorobenzene	%	86-115	97	98	96	97	-	-	Apr 26 2017
Monochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017
Monobromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017
Dichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017
Bromochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017
Dibromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017
Trichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017
Total HAA6	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	Apr 26 2017

THM & HAA RESULTS 2017

Sample	Unit of Measure	Nominal Detection Limit	Sample Location						Sampled Date
			Stevens Station	Stayte Station	Roper PRV - High	Marine Station	Everall Station	Mann Park Sation	
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Jul-17
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Jul-17
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Jul-17
Bromoform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Jul-17
Total THMs	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Jul-17
Dibromofluoromethane	%	86-118	103	97	100	98	-	-	25-Jul-17
Toluene-d8	%	85-115	<85	97	99	98	-	-	25-Jul-17
Bromofluorobenzene	%	86-115	99	98	98	100	-	-	25-Jul-17
Monochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Monobromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Dichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Bromochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Dibromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Trichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Total HAA6	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Jul-17
Chloroform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Oct-17
Bromodichloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Oct-17
Dibromochloromethane	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Oct-17
Bromoform	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Oct-17
Total THMs	mg/L	0.001	<0.001	<0.001	<0.001	<0.001	-	-	25-Oct-17
Dibromofluoromethane	%	86-118	92	99	96	91	-	-	25-Oct-17
Toluene-d8	%	85-115	89	88	85	90	-	-	25-Oct-17
Bromofluorobenzene	%	86-115	102	99	100	100	-	-	25-Oct-17
Monochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17
Monobromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17
Dichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17
Bromochloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17
Dibromoacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17
Trichloroacetic Acid	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17
Total HAA6	ug/L	2	<2.0	<2.0	<2.0	<2.0	-	-	25-Oct-17